



Industrie Service

Attestation No. IS-AN5-MUC-2011-758088-001

TÜV SÜD Industrie Service GmbH hereby confirms
that the rubber expansion joints (compensators) of the type ROTEX
made by

**ELAFLEX HIBY GmbH & Co. KG
Schnackenburgallee 121
22525 Hamburg**

were tested according to DIN 4809 Part 1 (published Nov. 1986).
The details of the tests are outlined in the pertinent reports.

The suitability of the ROTEX type series made of EPDM elastomer,
with nominal diameters from DN 25 to DN 300, for water heating
systems with maximum temperatures and pressures of 100°C / 10 bar
110°C / 6 bar was verified and ongoing internal factory inspection and
third-party surveillance confirmed.

ELAFLEX HIBY GmbH & CO. KG fulfils essential requirements,
including:

- Equipment which allows expert manufacturing and testing in line with the state of the art.
- Quality management system ensuring manufacturing and testing in line with the technical standards.
- Expert and professional manufacturing, assembly and test personnel.

This attestation will be valid up to the next required third-party surveillance in line with DIN 4809 Part 1 (published Nov. 1986).

Valid to: This attestation is valid to November 2025.

Munich, 05 November 2020

TÜV SÜD Industrie Service GmbH
Institute for Plastics


i. A. Schweizer

